

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1483:145 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

DESIGN: Models MIRBPS6, MIRBPS6C, MIRBPS10, MIRBPS10C, MIRBPS6220 and MIRBPS10220 booster power supplies. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: MIRBPS6, MIRBPS6C, MIRBPS10, MIRBPS10C: 120 VAC
MIRBPS6220, MIRBPS10220: 220 VAC

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. All installations must be in accordance with NFPA 72, 1999 Edition.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as booster power supply for use with listee's separately listed compatible fire alarm control units to extend the notification appliances circuit.

XLf: 7300-1388:225

01-05-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**